

Jessamine-South Elkhorn Water District

Water Quality Report 2023

Water System ID: KY0570249 Superintendent: Richard Decker CCR Contact: Richard Decker
Mailing Address: P.O. Box 731 Nicholasville, KY 40340
Meeting Location and Time: 802 S Main St, First Wednesday each month at 1:00 PM

Phone: 859-553-6346

Source Information:

We purchase our water from Kentucky American Water Company (serves Keene S. Elkhorn Rd), City of Nicholasville (serves southeast and northwest portions of Jessamine County), and Wilmore Utilities (serves two meters in Asbury College). All three systems treat surface water from the Kentucky River. Each of the producers has conducted an analysis of susceptibility to contamination and the overall susceptibility is considered moderate to moderately high. Areas of high concern include transportation corridors, underground and above ground storage tanks, agricultural land use, industrial sites, and waste generators. Kentucky River is most vulnerable to agricultural runoff, which may include pesticides, nutrients and pathogens. Activities and land use within the watershed can pose potential risks to your drinking water. These activities, and how they are conducted, are of interest to the entire community because they potentially affect your health and the cost of treating your water. The respective Source Water Assessment Plans are available for review at each of the water producers. Contact information for our suppliers can be obtained by calling our office at 859-881-0589.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information About Lead:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local water system is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact your local water system. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Some or all of these definitions may be found in this report:

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Below Detection Levels (BDL) - laboratory analysis indicates that the contaminant is not present.

Not Applicable (N/A) - does not apply.

Parts per million (ppm) - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L) - a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

To request a paper copy call (859) 881-0589.

To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. **Copies of this report are available upon request by contacting our office during business hours.**

Regulated Contaminant Test Results Jessamine-South Elkhorn Water District

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
Disinfectants/Disinfection Byproducts and Precursors							
Chlorine (ppm)	MRDL = 4	MRDLG = 4	0.94 (highest average)	0.79 to 1.06	2023	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	51 (high site average)	9.1 to 128 (range of individual sites)	2023	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	82 (high site average)	29.6 to 105 (range of individual sites)	2023	YES	Byproduct of drinking water disinfection.
Household Plumbing Contaminants							
Copper [1022] (ppm) Round 1 sites exceeding action level 0	AL = 1.3	1.3	0.0879 (90 th percentile)	0.00117 to 0.268	Aug-23	No	Corrosion of household plumbing systems
Unregulated Contaminants (UCMR 5)							
			average	range (ppb)	date		
Lithium			2.435	0 to 9.74	Dec-23		

Your drinking water has been sampled for a series of unregulated contaminants. Unregulated contaminants are those that EPA has not established drinking water standards. There are no MCLs and therefore no violations if found. The purpose of monitoring for these contaminants is to help EPA determine where the contaminants occur and whether they should have a standard. As our customers, you have a right to know that these data are available. If you are interested in examining the results, please contact our office during normal business hours.

2023-9443426

Testing results from 1/1/2023 to 3/31/2023 show that our system exceeds the standard, or maximum contaminant level (MCL), for trihalomethanes (THM). The standard for THM is 0.080 mg/L. It is determined by averaging all samples collected at each sampling location for the last 12 months. The level of THM averaged at one of our system's locations for 1/1/2023 to 3/31/2023 was 0.082 mg/L.

2023-9443427

Testing results from 4/1/2023 to 6/30/2023 show that our system exceeds the standard, or maximum contaminant level (MCL), for trihalomethanes (THM). The standard for THM is 0.080 mg/L. It is determined by averaging all samples collected at each sampling location for the last 12 months. The level of THM averaged at one of our system's locations for 4/1/2023 to 6/30/2023 was 0.081 mg/L.

We are working to minimize the formation of trihalomethanes while ensuring we maintain an adequate level of disinfectant. We have taken additional steps to increase flushing of water lines to determine if our efforts have been effective. We are also monitoring water storage tank levels and water flow patterns within the distribution system.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys or central nervous system, and may have an increased risk of getting cancer.

Public notices were distributed for each quarter we were out of compliance.

Regulated Contaminant Test Results Kentucky American (K) Nicholasville (N) Wilmore (W)										
Contaminant [code] (units)	MCL	MCLG	Source	Report Level	Range of Detection		Date of Sample	Violation	Likely Source of Contamination	
Inorganic Contaminants										
Barium [1010] (ppm)	2	2	N= W=	0.03	0.03	to	0.03	2023	No	Drilling wastes; metal refineries; erosion of natural deposits
				0.02	0.02	to	0.02	2023	No	
Fluoride [1025] (ppm)	4	4	K= N= W=	0.69	0.69	to	0.69	2023	No	Water additive which promotes strong teeth
				0.76	0.76	to	0.76	2023	No	
				0.90	0.90	to	0.90	2023	No	
Nitrate [1040] (ppm)	10	10	K= C=	0.18	0.18	to	0.18	2023	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
						to				
Disinfectants/Disinfection Byproducts and Precursors										
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	K= N= W=	1.05	0.68	to	1.56	2023	No	Naturally present in environment.
				1.36	0.99	to	2.08	2023	No	
				1.45	1.24	to	1.85	2023	No	
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.										
Other Constituents										
Turbidity (NTU) TT * Representative samples	Allowable Levels		Source	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity			
Turbidity is a measure of the clarity of the water and not a contaminant.	No more than 1 NTU*		K=	0.09	100	No	Soil runoff			
	Less than 0.3 NTU in		N=	0.21	100	No				
	95% monthly samples		W=	0.17	100	No				